





MP-... 4 100

Insulating mat class 4 - width 1 m.

Application:

CATU Electrical Insulating Mats conform to IEC 61111:2009 and are manufactured using high quality elastomer rubber in order to provide complete protection against electric shock, isolating users from potentially life-threatening electrical currents..

CATU Electrical Insulating Mats are suitable for use in outdoor and indoor applications and are generally placed in front of electrical panels, switch gears & high voltage equipment in order to create a safe working environment for the operators/users.

The choice of the class **must** be determined according to the maximal nominal voltage of the network.

Rigorous testing to conform to the IEC 61111:2009 standard includes:

• Puncture resistance test

• Flame retardance test

• Dielectric test

Acid resistance test

Ageing test
 Oil resistance test

Features:

- Insulating mat for live and dead working.
- Class 4 Maximum operating voltage: 36 000 V AC 54 000 V DC.
- Used to cover the floor for the electrical protection of operators in electrical installations.
- · Protect the workers from the ground potential.
- Must be adapted to the nominal voltage of the network supplying the installation on which it is used.
- In accordance with IEC 61111:2009 standard and to specific properties of the "C" Category (extremely low temperature folding test at – 40 °C).
- RoHS2 compliant. REACH compliant (SVHC free).
- Material: elastomer, halogen free.
- Thickness: 5mm +/-0.2mm.
- D bar code (Datamatrix) on marking with direct link to user guide and technical sheet.
- Storage temperature: +10°C to +21°C.
- Operating temperature: -40°C to +55°C.



Reference		Voltage		Dimensions			
	Class	Operating Voltage AC	Operating Voltage DC	Length (mm)	Width (mm)	Thickness (mm)	Weight (kg)

 $\mbox{UID}: |\mbox{ TID}: :: 01/01/1970| \mbox{ SID}: :: 01/01/1970 \mbox{ }| \mbox{ Issued}: 04/21/2025 \mbox{ }08:55:19 \mbox{ }pm$

Last Modification: 04/15/2025

SICAME GROUP









MP-100/05-1 4 36 000 V 54 000 V 1 000 1 000 5 8,9

 $\mbox{UID}: |\mbox{ TID}: :: \mbox{01/01/1970}| \mbox{ SID}: :: \mbox{01/01/1970}| \mbox{ Issued}: \mbox{04/21/2025} \mbox{ 08:55:19 pm}$

Last Modification : 04/15/2025

CATU S.A.S. - 10, Avenue Jean-Jaurès - B.P.2 - 92222 Bagneux Cedex France
Phone : +33 1 42 31 46 00 - Fax : +33 1 42 31 46 32

SICAME GROUP